

GPR-H500-A SPECIFICATIONS



TO :

CAT.NO.	PRODUCT NAME
GPR-H500-A	DC RELAY

	Rev. No	Content	Page
R e v i s i o n			

REMARKS :

ACCEPTABILITY OF SPECIFICATION :

ACCEPTED BY :

ON :

PLEASE CONTACT....

AEC Inc., 1101 Lafayette Street, Elkhart, Indiana 46516, USA. www.aecensors.com

Toll: 888 847 6552, Tel: +1 574 295 6330, Fax: +1 574-293-8013, sales@aecensors.com

LS ELECTRIC Co.,Ltd	DATE	APPROVED BY
	NOV. 30. 2021	
	PREPARED BY: RE	CHECKED BY

DC RELAY SPECIFICATIONS				LS ELECTRIC Co.,Ltd
MODEL	GPR-H500-A	PAGE	1/7	

- 1) Type ; GPR-H500-A
 2) Characteristics

2-1. Rating

Frame		GPR-H500-A		
Pole (P)		1		
Rated insulation voltage (Ui)		DC1500V		
Rated impulse withstand voltage (Uimp)		8kV		
Rated operational voltage (Ue)		DC1500V		
Rating	Continuous current (Ith)		500A	
	Rated operational Current Ie (A)	L/R<1mS	DC1500V	200A
		L/R<1mS	DC1000V	300A
	Short Time withstand Current	120s		900A
		15Min		750A

2-2. Coil Data


Frame	GPR-H500-A	
Rated Voltage	12VDC	24VDC
Pick-up Voltage (Initial at 20°C)	Max. 9VDC	Max. 18VDC
Drop-out Voltage (Initial at 20°C)	Min. 1.2VDC	Min. 2.4VDC
Max. Allowable Voltage	15VDC	30VDC
Rated Inrush Current (at 20°C)	4.6A	2.3A
Power Consumption (at 20°C)	5.0W	5.0W
Coil Resistance (at 20°C)	2.6Ω/29Ω (±10%)	9.5Ω/110Ω (±10%)

2-3. Contact Data

1. Max. Continuous current ; 500A (Conductor 300mm²)
2. Min. Continuous current ; 1A, DC24V
3. Max. switching current ; 300A(L/R<1mS) at DC1500V 100 Cycles (Breaking Only)
 250A(L/R<1mS) at DC1500V 250 Cycles
 200A(L/R<1mS) at DC1500V 1,000 Cycles
 100A(L/R<1mS) at DC1500V 6,000 Cycles
 300A(L/R<1mS) at DC1000V 1,000 Cycles
 320A(L/R<1mS) at DC1000V 1,000 Cycles
 320A(L/R<1mS) at DC1220V 250 Cycles
 400A(L/R<1ms) at DC1250V 100 Cycles
 500A(L/R<1ms) at DC1250V 50 Cycles
 1,250A(L/R<1ms) at DC1250V 1 Cycle
 800A(L/R<1ms) at DC1500V 1 Cycle

DC RELAY SPECIFICATIONS			LS ELECTRIC Co.,Ltd
MODEL	GPR-H500-A	PAGE	2/7

4. Contact Voltage Drop(Initial) ; 0.04V @ 20A
5. Aux, Contact Current, Max ; DC30V 100mA
6. Aux, Contact Current, Min ; DC7.5V 1.5mA



2-4. Expected Life

1. Electrical Life (L/R<1mS) ; DC1500V 300A 100ops.(120 Cycles/h) -Breaking Only-
(L/R<1mS) ; DC1500V 250A 200ops.(180 Cycles/h)
(L/R<1mS) ; DC1500V 200A 1,000ops.(360 Cycles/h)
(L/R<1mS) ; DC1500V 100A 6,000ops.(360 Cycles/h)
(L/R<1mS) ; DC1000V 300A 1,000ops.(360 Cycles/h)
(L/R<1mS) ; DC1000V 320A 1,000ops.(360 Cycles/h)
(L/R<1mS) ; DC1220V 320A 250ops.(180 Cycles/h)
2. Reverse Direction Switch-off Life ; Same above
3. Mechanical ; Min. 200,000ops.(3600 Cycles/h)

2-5. Initial Breakdown Voltage

1. Between Open Contacts ; 4500Vrms/min (Detection current : 10mA)
2. Between Contacts and Coil ; 4500Vrms/min (Detection current : 10mA)
3. Between Contacts and Frame ; 4500Vrms/min (Detection current : 10mA)
4. Between Coil and Frame ; 4500Vrms/min (Detection current : 10mA)

- 2-6. Initial Insulation Resistance ; Min. 100MΩ (at DC1000V)
(Between Coil and Contacts/Between contacts of the same polarity)

DC RELAY SPECIFICATIONS			LS ELECTRIC Co.,Ltd
MODEL	GPR-H500-A	PAGE	3/7

2-7. Vibration Resistance

- 1. Functional ; 10 to 1000 Hz @1.0G
(Detection Time: 250µs, Time of vibration for each X,Y,Z direction : 8 hours)
- 2. Destructive ; 10 to 200Hz in increments of 10 @Min. 4.5G
(Time of vibration for each X,Y,Z direction : 4 hours)

2-8. Shock Resistance

- 1. Functional ; 49m/s² (5G)
(Relay On: 11ms half sine, 250µs detection time)
- 2. Destructive ; 196m/s² (20G)
(Relay On: 9ms half sine wave)

2-9. Operate time (at 20°C, Main Terminal) ; Max. 35ms

2-10. Release time (at 20°C, Main Terminal) ; Max. 15ms

2-11. Tightening torque

- 1. Mounting Hole (M6) ; 6 to 8 N·m
- 2. Main Terminal (M8) ; 9 to 12 N·m

2-12. Unit Weight ; Approx. 1.3kg

3) Operation, Transport, Storage

(Following is the condition of ambient temperature and humidity in case of operation, transport and storage.)

- 3-1. Ambient Temperature ; -40 to 85°C
 - Frame : below 120°C (RTI, Ambient Temperature 70°C)
 - Main Terminal : below 135°C (below ∇T 65°C, Ambient Temperature 70°C)
 - Coil : below 150°C (below ∇T 80°C, Ambient Temperature 70°C)
- 3-2. Ambient Humidity ; 5 to 95%RH
- 3-3. Storage Temperature ; -40 to 85°C
- 3-4. Storage Humidity ; 5 to 95%RH

4) Degrees of protection of enclosed equipment IP ; IP40


5) Short-Circuit Current (FUSE Combination) ; 10KA / 400A FUSE DC2000V (Bussmann, 170M2043)
; 10KA / 200A FUSE DC1500V (Vicfuse, VD2 BB-K)

6) CE & UL & CCC Certificated (IEC60947-4-1, UL60947-4-1, GB/T14048.4)

DC RELAY SPECIFICATIONS			LS ELECTRIC Co.,Ltd
MODEL	GPR-H500-A	PAGE	4/7


7) Product Design & Accessories

Coil Terminal Accessory



Housing : MG651026(L)		Terminal : ST730676-3		Accessory(Not included)		
Part No.	Wire Range		Tab Thick	Material		Components Coil Terminal Accessory : 1EA Wire length : 300mm Nut M8 2EA Spring-Washer 2EA Plane-Washer 2EA
	AWG	mm ²		Thick	Finish	
ST730676-3	18-16	AVSS(CAVS) 0.85~1.25	0.64	0.25	Copper Alloy Pre-Tin	


8) Dimension




General Tolerance
 Less Than 10: ±0.25 / 10~50: ±0.5
 More Than 50: ±0.8

9) Engineering Data

Carry Current (Continuous, 300mm²)



Switching Life (Making & Breaking)



DC RELAY SPECIFICATIONS			LS ELECTRIC Co.,Ltd
MODEL	GPR-H500-A	PAGE	6/7

10) Cautions For Use

- Please refer to the general catalog for technical terms and specific cautions for use.
- Pick-up and drop-out voltages should be adjusted to the ambient conditions and temperature for the application of your product.
- The repeated turn-off of the coil (during inrush time or in high coil current) when a relay is powered may cause damage to the relay (built-in electric circuit block). So the coil should not be turned off during the process of inrush.
- Lifetime is specified under the standard test conditions (temperature 15 to 35 , humidity 25 to 86%RH) and is determined according to load type, operation frequency, coil driving circuit, and ambient conditions.
- The relay which is used in the condition exceeding coil rating, contact rating or cycle lifetime may cause overheating.
- The slow escalation of the coil voltage may cause the relay unable to be turned on. Therefore allow coil the voltage quickly.
- Avoid the cross-connection for it may cause malfunctioning or overheating.
- When the screw and nut are tightened to the fixed relay housing or main circuit terminal, it should be used within the range of torque specified in the catalog.
- If relays are closely mounted or placed close to a heat-generating object, carefully check the abnormal temperature rise and the distance of insulation between the terminals outside the relay, and keep the distance between relays to the minimum of 10mm.
- Avoid the sticking of oil and foreign substances to the main terminal part since this may cause the terminal part to emit unusual heat. Also the tightening torque should be applied as recommended when running branches off from the main terminals.
- Be careful in handling the relay when using or storing it in a high temperature environment since the relay contacts are encapsulated in an inert atmosphere.
- If the nominal voltage and current are continuously applied to the coil and a relay is switched off and then on immediately, the coil temperature will rise, leading to the improvement of the relay coil resistance. This will make the pull-in voltage soar to surpass the nominal value. To avoid such situation, it is recommended to take precautions such as increasing load current, restricting time to apply voltage, applying high coil voltage and then nominal voltage, etc.
- In case of using a capacitive load (C-load), take precautions such as pre-charging to the capacitive load in order to prevent the inrush current from exceeding the rated current
- In case of using an inductive load of L/R 1ms, take precautions such as putting surge absorbers in parallel in order to avoid the shortening of electrical life or mis-contact-related problem
- Use the bus bar or wire appropriate to the specific current. For example, the wire with a narrow diameter does not ensure the maximum allowable rated current to contacts.
- Avoid mounting the relay in strong magnetic fields (near a transformer or magnet) or close to an object that radiates heat.
- If relays are proximately installed each other or installed near highly-magnetized parts such as motor and speaker, the relay may change its operational characteristics or cause malfunction. Therefore, after mounting, check performance in actual operational conditions.
- If a product such as a current sensor is installed near the relay, check performance in actual operational conditions.
- Make sure The power supply is disconnected while wiring
- Do not pull with the force of more than 0.5N when pulling a female connector lead wire on the opposite side. Do not give any shock to a relay or it may have some trouble.
- This product is not waterproof. If you want to install it in a place where waterproofing is required, please develop a measure to satisfy the requirement.
- Avoid using the product in the environment in which an organic solvent (e.g. alcohol, benzene, or thinner) and a strong alkali (ammonia or caustic soda) can be easily adhered to the product.
- Additional production should not be implemented on the relay housing.

DC RELAY SPECIFICATIONS			LS ELECTRIC Co.,Ltd
MODEL	GPR-H500-A	PAGE	7/7

10) Cautions For Use

- The product can be used under 2000m without performance derating by altitude.
- The product can be used under 2000~4000m under DC1500V system.
And after verification, the product could be used under DC1500V system , but other performance would be derating by altitude (Please refer to the table below)
- Higher than 4000m ,please contact with LSIS(Less than DC1500V system).
- Please consider about the derating by altitude of clearance between the relay and other electrical structure.

Altitude	Derating Factor	
	Rated Operating Voltage	Continuous Current
2000m	1.00	1.00
3000m	0.91	0.98
4000m	0.82	0.96
5000m	0.73	0.94

- All Temperature rising & Carry current data of Specification on main terminal should be less than 65K